



Product Service

Attestation of Conformity

No. N8A 104598 0012 Rev. 01

Holder of Certificate: **Mysolar Manufacturing (Shanghai)Co.,Ltd.**
Room J8097, Bldg 2,
No. 4268, Zhennan Rd
Jiading District
201800 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062032801-01

Date, 2021-06-18

(Zhulin Zhang)

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 104598 0012 Rev. 01

Model(s):

Maximum System Voltage: 1000 V DC Modules:
 MSxxxM-SLS,xxx=385 to 430 in step of 5W;
 MSxxxM-SLS,xxx=345 to 370 in step of 5W;
 MSxxxM-SLS,xxx=315 to 350 in step of 5W;
 MSxxxM-HS,xxx=370 to 410 in step of 5W;
 MSxxxM-HS,xxx=310 to 340 in step of 5W;

Maximum System Voltage: 1500 V DC Modules:
 MSxxxMH-SLS,xxx=385 to 430 in step of 5W;
 MSxxxMH-SLS,xxx=345 to 370 in step of 5W;
 MSxxxMH-SLS,xxx=315 to 350 in step of 5W;
 MSxxxMH-HS,xxx=370 to 410 in step of 5W;
 MSxxxMH-HS,xxx=310 to 340 in step of 5W;
 MSxxxM-HP,xxx=425 to 455 in step of 5W;
 MSxxxM-HP,xxx=355 to 380 in step of 5W;
 MSxxxM-HA,xxx=535 to 545 in step of 5W;
 MSxxxM-HA,xxx=490 to 500 in step of 5W;
 MSxxxM-HA,xxx=445 to 455 in step of 5W;
 MSxxxM-HA,xxx=405 to 410 in step of 5W;

All electrical data is shown as relative to standard test conditions:

front side irradiance 1000 W/m², 25 °C, AM 1.5)

MSxxxM-DHBS,xxx=360 to 415 in step of 5W;
 MSxxxM-DHBS,xxx=300 to 345 in step of 5W;
 MSxxxM-DHBP,xxx=420 to 455 in step of 5W;
 MSxxxM-DHBP,xxx=350 to 380 in step of 5W;
 MSxxxN-DHBP,xxx=410 to 425 in step of 5W;
 MSxxxN-DHBP,xxx=340 to 355 in step of 5W;
 MSxxxN-DHBS,xxx=390 to 415 in step of 5W;
 MSxxxN-DHBS,xxx=325 to 345 in step of 5W;
 MSxxxM-DHBA,xxx=530 to 545 in step of 5W;
 MSxxxM-DHBA,xxx=485 to 500 in step of 5W;
 MSxxxM-DHBA,xxx=440 to 455 in step of 5W;
 MSxxxM-DHBA,xxx=400 to 410 in step of 5W;

All electrical data is shown as relative to this test conditions:

front side irradiance 1000 W/m²,

backside irradiance 200 W/m², 25 °C, AM 1.5

MSxxxM-DHBSB,xxx=420 to 465 in step of 5W;
 MSxxxM-DHBSB,xxx=350 to 385 in step of 5W;
 MSxxxM-DHBPB,xxx=475 to 515 in step of 5W;
 MSxxxM-DHBPB,xxx=395 to 430 in step of 5W;
 MSxxxN-DHBPB,xxx=475 to 490 in step of 5W;
 MSxxxN-DHBPB,xxx=395 to 405 in step of 5W;
 MSxxxN-DHBSB,xxx=450 to 475 in step of 5W;
 MSxxxN-DHBSB,xxx=375 to 395 in step of 5W;
 MSxxxM-DHBAB,xxx=610 to 625 in step of 5W;
 MSxxxM-DHBAB,xxx=560 to 570 in step of 5W;
 MSxxxM-DHBAB,xxx=510 to 520 in step of 5W;



Product Service

Attestation of Conformity

No. N8A 104598 0012 Rev. 01

MSxxxM-DHBAB,xxx=460 to 470 in step of 5W;
xxx is standing for rated output power at STC.

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC or 1000V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Construction:	Framed or Frameless, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06