



Product Service

# CERTIFICATE

No. Z2 104598 0001 Rev. 02

**Holder of Certificate:** **Mysolar Manufacturing (Shanghai)Co.,Ltd.**

Room J8097, Bldg 2,  
No. 4268, Zhennan Rd  
Jiading District  
201800 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:****Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 701261906201-02**Valid until:** 2025-01-06**Date,** 2020-03-11( Zhulin Zhang )  




Product Service

# CERTIFICATE

No. Z2 104598 0001 Rev. 02

## Model(s):

MSxxxM-S, xxx=95 to 405 in step of 5,  
 MSxxxM-S, xxx=75 to 85 in step of 5,  
 MSxxxM-S, xxx=40 to 65 in step of 5,  
 MSxxxM-S, xxx=30 or 20 or 10,  
 MSxxxM-H, xxx=370 to 405 in step of 5,  
 MSxxxM-H, xxx=310 to 340 in step of 5,  
 xxx is standing for rated output power at STC

## Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class :	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL 790 Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.
Test Laboratory:	

## Tested according to:

IEC 61215-1(ed.1)  
 IEC 61215-1-1(ed.1)  
 IEC 61215-2(ed.1)  
 IEC 61730-1(ed.2)  
 IEC 61730-2(ed.2)  
 EN 61215-1:2016  
 EN 61215-1-1:2016  
 EN 61215-2:2017  
 EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

## Production Facility(ies):

054757

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
 ZERTIFIKAT • CERTIFICATE • 認證證書 • CERTIFICADO • CERTIFICAT